



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Noor-Ul-Iman, #8989, 4137 Route 1 South, Monmouth Junction, NJ 08852
PAS Project ID : P24-08541

Matrix : Drinking Water
Report Date : 8/15/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08541-01	NUI-1-B-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:27	8/12/24 12:10
P24-08541-02	NUI-1-B-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:32	8/12/24 12:28
P24-08541-03	NUI-1-B-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:36	8/12/24 12:41
P24-08541-04	NUI-1-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:40	8/12/24 12:45
P24-08541-05	NUI-1-B-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:42	8/12/24 12:50
P24-08541-06	NUI-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:48	8/12/24 12:54
P24-08541-07	NUI-1-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:48	8/12/24 12:59
P24-08541-08	NUI-1-B-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:52	8/12/24 13:03
P24-08541-09	NUI-1-B-06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:55	8/12/24 13:08
P24-08541-10	NUI-1-B-07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:59	8/12/24 13:12
P24-08541-11	NUI-1-B-08A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:03	8/12/24 13:17
P24-08541-12	NUI-1-B-09A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:07	8/12/24 13:30
P24-08541-13	NUI-1-B-10A	Lead	1.23 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:11	8/12/24 13:35
P24-08541-14	NUI-1-B-11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:14	8/12/24 13:39
P24-08541-15	NUI-1-B-12A	Lead	1.23 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:19	8/12/24 13:44
P24-08541-16	NUI-1-B-13A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:23	8/12/24 13:49
P24-08541-17	NUI-1-B-14A	Lead	1.46 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:27	8/12/24 13:53
P24-08541-18	NUI-1-B-15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:31	8/12/24 13:58
P24-08541-19	NUI-1-B-16A	Lead	1.23 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:38	8/12/24 14:02
P24-08541-20	NUI-2-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:47	8/12/24 14:07
P24-08541-21	NUI-2-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:49	8/12/24 14:20
P24-08541-22	NUI-2-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 09:57	8/12/24 14:25
P24-08541-23	NUI-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:25	8/12/24 14:42

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: Noor-UI-Iman ۞ ۞ ۞ ۞
School Address: 4137 Route 1 South, Monmouth Junction, NJ 08852
Sampled By: *Caroline Poskrobko*
Print Name: Caroline Poskrobko
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
NUI-1-B-01A; Room 110	8:27 AM	DW	Grab			1	250 ml Plastic	Lead	824-085411-01
NUI-1-B-02A; Room 109	8:32 AM	DW	Grab			1	250 ml Plastic	Lead	02
NUI-1-B-03A; Room 108	8:36 AM	DW	Grab			1	250 ml Plastic	Lead	03
NUI-1-S-01A; Nurse Room 116	8:40 AM	DW	Grab			1	250 ml Plastic	Lead	04
NUI-1-B-04A; Room 107	8:42 AM	DW	Grab			1	250 ml Plastic	Lead	05
NUI-1-WC-01A; Main Lobby Left	8:48 AM	DW	Grab		X	1	250 ml Plastic	Lead	06
NUI-1-WC-02A; Main Lobby Right	8:48 AM	DW	Grab		X	1	250 ml Plastic	Lead	07
NUI-1-B-05A; Room 104	8:52 AM	DW	Grab			1	250 ml Plastic	Lead	08
NUI-1-B-06A; Room 103	8:55 AM	DW	Grab			1	250 ml Plastic	Lead	09
NUI-1-B-07A; Room 102	8:59 AM	DW	Grab			1	250 ml Plastic	Lead	10
NUI-1-B-08A; Room 101	9:03 AM	DW	Grab			1	250 ml Plastic	Lead	11
NUI-1-B-09A; Room 128	9:07 AM	DW	Grab			1	250 ml Plastic	Lead	12
NUI-1-B-10A; Room 129	9:11 AM	DW	Grab			1	250 ml Plastic	Lead	13
NUI-1-B-11A; Room 131	9:14 AM	DW	Grab			1	250 ml Plastic	Lead	14
NUI-1-B-12A; Room 133	9:19 AM	DW	Grab			1	250 ml Plastic	Lead	15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 2

Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO3: 8/8/24 13:40

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Caroline Poskrobko	<i>Caroline Poskrobko</i>	GSE	8/5/2024, 10:15 AM
Received:	<i>Darryl Hodges</i>	<i>Darryl Hodges</i>	PAS	8/7/24 1127
Relinquished:	<i>Darryl Hodges</i>	<i>Darryl Hodges</i>	PAI	8/7/24 604
Received:	<i>Darryl Hodges</i>	<i>Darryl Hodges</i>		
Relinquished:	<i>date Mathews</i>	<i>K. Mathews</i>		8/8/24 11AM
Received:	<i>date Mathews</i>	<i>K. Mathews</i>		

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: Noor-UI-Iman न ११ १७
School Address: 4137 Route 1 South, Monmouth Junction, NJ 08852
Sampled By: *Caroline Poskrobko*
Print Name: Caroline Poskrobko
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NUI-1-B-13A; Room 135	9:23 AM	DW	Grab			1	250 ml Plastic	Lead	024-08541- 024-08685 16
NUI-1-B-14A; Room 138	9:27 AM	DW	Grab			1	250 ml Plastic	Lead	17
NUI-1-B-15A; Room 141	9:31 AM	DW	Grab			1	250 ml Plastic	Lead	18
NUI-1-B-16A; Room 142	9:38 AM	DW	Grab			1	250 ml Plastic	Lead	19
NUI-2-WC-03A; 2nd Floor By 218 Left	9:47 AM	DW	Grab		X	1	250 ml Plastic	Lead	20
NUI-2-BF-02A; 2nd Floor By 218 Left	9:49 AM	DW	Grab		X	1	250 ml Plastic	Lead	21
NUI-2-WC-04A; 2nd Floor By 218 Right	9:57 AM	DW	Grab		X	1	250 ml Plastic	Lead	22
NUI-8-2-FBA; Field Blank		DW	Grab			1	250 ml Plastic	Lead	23
		DW	Grab			1	250 ml Plastic	Lead	24
		DW	Grab			1	250 ml Plastic	Lead	25
		DW	Grab			1	250 ml Plastic	Lead	26
		DW	Grab			1	250 ml Plastic	Lead	27
		DW	Grab			1	250 ml Plastic	Lead	28
		DW	Grab			1	250 ml Plastic	Lead	29
		DW	Grab			1	250 ml Plastic	Lead	30

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 2 of 2

Deliverables: PDF Std. X, PDF Reduce, PDF Full, EDD, Date/Time Preserved with HNO3.

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Caroline Poskrobko	<i>Caroline Poskrobko</i>	GSE	8/5/2024, 10:15 AM
Received:	<i>Perry Hodges</i>	<i>Perry Hodges</i>	PAS	8/7/24 1123
Relinquished:	<i>Perry Hodges</i>	<i>Perry Hodges</i>	PAS	8/17/24 1648
Received:				
Relinquished:				
Received:				